

## Classification Report

Number	18-001407-PR04 (NW-C01-02-en-01)
Owner	profine GmbH Kömmerling Kunststoffe Zweibrücker Str. 200 66954 Pirmasens Germany
Product	Double leaf external pedestrian doorset, inward opening
Designation	System: KBE 76mm KÖ 76mm TROCAL 76mm
Details	Material Unplasticised polyvinyl chloride (uPVC), with reinforcement; Overall dimensions (W x H) 2118 mm x 2496 mm; Closing condition closed and locked – in main latchbolt and auxiliary latchbolts; Threshold: Designation Threshold with thermal barrier A076; System KBE 76mm KÖ 76mm TROCAL 76mm; Material Aluminium system with thermal break; Main lock: Designation Multi-point locking system with latchbolt, deadbolt and automatically latchbolts STV-AV2-F2036 L20/55 92/8 M2 RS MC Nr. 5001964, Fa. Winkhaus
Special features	Watertightness was carried out with additional floor simulation (reduced water level).

### Result

Air permeability according to EN 12207:2016-12



**Class: 3**

Resistance to wind load according to EN 12210:2016-03



**Class: C2/B2**

Watertightness according to EN 12208:1999-11



**Class: 4A**

ift Rosenheim  
25.04.2019



Peter Marquardt, Dipl.-Ing. (FH)  
Deputy Head of Testing Department  
Building Component Testing



Daniel Gromotka, B.Eng.  
Operating Testing Officer  
Building Component Testing

### Basis \*)

EN 14351-1:2006+A2:2016-09  
\*) and corresponding national versions  
(e.g. DIN EN)

Test report: 18-001407-PR04 PB-  
C01-02-de-01

### Representation



### Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

### Validity

There is no time limit.  
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

### Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

### Identity-Check



[www.ift-rosenheim.de/ift-geprueft](http://www.ift-rosenheim.de/ift-geprueft)  
ID: F5D-A9D27