

ift-Nachweis

Classification Report



Number	18-002835-PR08 (NW-A01-020310-en-01)
Owner	profine GmbH Kömmerling Kunststoffe Zweibrücker Str. 200 66954 Pirmasens Germany
Product	T-connector
Designation	System: KBE 76 AD KÖMMERLING 76 AD TROCAL 76 AD Shipping name: J052
Details	Manufacturer profine GmbH, Kömmerling Kunststoffe - Pirmasens; Material Unplasticised polyvinyl chloride (uPVC), with reinforcement; Type of opening Turn; Opening direction DIN right, inward opening; Overall dimensions (W x H) 1200 mm x 1200 mm
Special features	

Result

Watertightness after thermal and mechanical load according to ift-Richtlinie FE-06/2 2017-02




Requirement: fulfilled

Basis *)

ift-Richtlinie FE-06/2 2017-02
*) and corresponding national versions
(e.g. DIN EN)

Test report: 18-002835-PR08 PB-
A01-020310-de-01

Representation



Instructions for use

The construction of the tested mechanical connection as described in the Annex of the Test Report can be released for the production of quality-controlled PVC-windows. In order to supplement the system description the mounting instruction has to be forwarded to the processors of the relevant profile system, that have been members of the RAL Quality Association.

Validity

There is no time limit.
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

ift Rosenheim
17.06.2019

Thomas Krichbaumer
Deputy Head of Testing Department
Building Component Testing

Daniel Gromotka, B.Eng.
Operating Testing Officer
Building Component Testing

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: 383-A58A9